



Certificado AENOR de Producto



042/001171

AENOR certifica que la organización

GRUPO GENERAL CABLE SISTEMAS, S.L.

con domicilio social en CALLE DEL METALL, 4 POLIGONO INDUSTRIAL CAN SUCARRATS
08630 ABRERA (Barcelona - España)

suministra **Cable con resistencia intrínseca al fuego, destinado a circuitos de seguridad, con aislamiento polietileno reticulado y cinta de mica y cubierta de poliolefina, conductor flexible (0,6/1kV).**

conforme con UNE 211025:2020

Designación RZ1-K (AS+)
Marca Comercial GENERAL CABLE [SAP] SEGURFOC CLASS
Limitación De 1x1,5 mm² a 1x500 mm²; De 2x1,5 mm² a 2x35 mm²;
De 3x1,5 mm² a 3x35 mm²; De 4x1,5 mm² a 4x240 mm²; 4x25+1x16 mm²;
De 5x1,5 mm² a 5x50 mm²;

Resistencia al Fuego PH 120

Centro de producción P.I. CAN VINYALET, 2
08130 SANTA PERPÈTUA DE LA MOGODA (Barcelona - España)

Esquema de certificación Para conceder este Certificado, AENOR ha ensayado el producto y ha comprobado el sistema de la calidad aplicado para su elaboración. AENOR realiza estas actividades periódicamente mientras el Certificado no haya sido anulado, según se establece en el Reglamento Particular RP 042.01.

Este certificado anula al 042/001171, de fecha 2022-06-23

Primera emisión 2022-06-13
Modificación 2023-08-31
Expiración 2027-06-13

Rafael GARCÍA MEIRO
CEO





AENOR Product Certificate



042/001171

AENOR certifies that the organization

GRUPO GENERAL CABLE SISTEMAS, S.L.

registered office CALLE DEL METALL, 4 POLIGONO INDUSTRIAL CAN SUCARRATS
08630 ABRERA (Barcelona - Spain)

supplies **Cable with intrinsic resistance to fire, intended for use in emergency circuits, insulated with XLPE and mica tape; polyolefin sheathed; flexible conductor (0,6/1kV).**

in compliance with UNE 211025:2020

Designation RZ1-K (AS+)
Trade Mark GENERAL CABLE [SAP] SEGURFOC CLASS
Restriction From 1x1,5 mm² to 1x500 mm²; From 2x1,5 mm² to 2x35 mm²;
From 3x1,5 mm² to 3x35 mm²; From 4x1,5 mm² to 4x240 mm²;
4x25+1x16 mm²; From 5x1,5 mm² to 5x50 mm²;

Resistance to Fire PH120

Production site P.I. CAN VINYALET, 2
08130 SANTA PERPÈTUA DE LA MOGODA (Barcelona - Spain)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 042.01.

This certificate supersedes 042/001171, dated 2022-06-23

First issued on 2022-06-13
Modified on 2023-08-31
Validity 2027-06-13

Rafael GARCÍA MEIRO
CEO

