

AENOR

Certificado AENOR de Producto Cables eléctricos de distribución



075/000224

AENOR certifica que la organización

GRUPO GENERAL CABLE SISTEMAS, S.L.

con domicilio social en	CALLE DEL METALL, 4 POLIGONO INDUSTRIAL CAN SUCARRATS 08630 ABRERA (Barcelona - España)
suministra	Cable eléctrico de distribución en media tensión con aislamiento de polietileno reticulado, pantalla de tubo de aluminio y cubierta de poliolefina. Sin propiedades especiales ante la reacción al fuego.
conforme con	UNE 211620:2020
Designación	RH5Z1-OL AL
Marca Comercial	GENERAL CABLE [CNE] HERSATENE CLASS
Tensión de Servicio U _o /U (Um)	12/20 (24) kV; 18/30 (36) kV
Limitación	Conductor de Aluminio (K AL): 1x50 mm ² ; 1x95 mm ² ; 1x150 mm ² ; 1x185 mm ² ; 1x240 mm ² ; 1x400 mm ² ; 1x630 mm ² .
Tipo	10E-6
Centro de producción	CR C-15 KM 2. PI. MASIA D'EN NOTARI 08800 VILANOVA i LA GELTRÚ (Barcelona - España)
Esquema de certificación	Para conceder este Certificado, AENOR ha ensayado el producto y ha comprobado el sistema de la calidad aplicado para su elaboración. AENOR realiza estas actividades periódicamente mientras el Certificado no haya sido anulado, según se establece en el Reglamento Particular RP 075.02. Este certificado anula y sustituye al 075/000224, de fecha 2022-01-31
Fecha de primera emisión	2020-01-16
Fecha de modificación	2022-03-11
Fecha de expiración	2027-01-27


Rafael GARCÍA MEIRO
Director General

Original Electrónico

AENOR INTERNACIONAL SAU.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Entidad de certificación de producto acreditada por ENAC con acreditación n° 1/C-PR275

AENOR

AENOR Product Certificate Electric distribution cables



075/000224

AENOR certifies that the organization

GRUPO GENERAL CABLE SISTEMAS, S.L.

registered office	CALLE DEL METALL, 4 POLIGONO INDUSTRIAL CAN SUCARRATS 08630 ABRERA (Barcelona - Spain)
supplies	Medium Voltage Power Distribution electric cable, XLPE insulated, with tubular aluminium screen and PO sheathed. Without special reaction to fire characteristics.
in compliance with	UNE 211620:2020
Designation	RH5Z1-OL AL
Trade Mark	GENERAL CABLE [CNE] HERSATENE CLASS
Rated Voltage U _o /U (Um)	12/20 (24) kV; 18/30 (36) kV
Restriction	Aluminium Conductor (K AL): 1x50 mm ² ; 1x95 mm ² ; 1x150 mm ² ; 1x185 mm ² ; 1x240 mm ² ; 1x400 mm ² ; 1x630 mm ² .
Type	10E-6
Production site	CR C-15 KM 2. PI. MASIA D'EN NOTARI 08800 VILANOVA I LA GELTRÚ (Barcelona - Spain)
Certification scheme	In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 075.02. This certificate supersedes 075/000224, dated 2022-01-31
First issued on	2020-01-16
Modified on	2022-03-11
Validity date	2027-01-27


Rafael GARCÍA MEIRO
Chief Executive Officer

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Product certification body accredited by ENAC, number 1/C-PR275