

Certificate No: **TAE00002ZB** 

# TYPE APPROVAL CERTIFICATE

| This is to certify:   |                           |  |
|---|---------------------------|--|
| That the Electric Power Cable   |                           |  |
| with type designation(s) TEOF or EXZHELLENT 606 P18 RU or RU MUD 0,6/1 kV   |                           |  |
| Issued to PRYSMIAN CABLES SPAIN, S.A. Vilanova i la Geltrú, Barcelona, Spain                                      |                           |  |
| is found to comply with DNV GL rules for classification – Ships, offshore units, and high sp                      | peed and light craft      |  |
| Application:  |                           |  |
| General power and lighting. Control.  Products approved by this certificate are accepted for installation DNV GL. | on all vessels classed by |  |
| Rated voltage (kV) 0,6/1 Temp. class (°C) 90  |                           |  |
| Issued at <b>Høvik</b> on <b>2019-12-04</b>   |                           |  |
| This Certificate is valid until <b>2023-06-30</b> .  DNV GL local station: <b>Barcelona</b>                       | for <b>DNV GL</b>         |  |

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Approval Engineer: Ivar Bull

Form code: TA 251 Revision: 2016-12 www.dnvgl.com Page 1 of 3

Trond Sjåvåg Head of Section

Job Id: **262.1-015325-7** Certificate No: **TAE00002ZB** 

## **Product description**

Type: TEOF or EXZHELLENT 606 P18 RU or RU MUD 0,6/1 kV

Construction:

Conductors: Tinned, stranded annealed copper Class 2 or

Class 5

Core insulation: EPR

Outer sheath: SHF2 or SHF Mud

| No of cores:  | Cross sectional area [mm <sup>2</sup> ] |
|---|---|
| 1   | 1,5 - 300                               |
| 2, 4  | 1 - 120                                 |
| 3   | 1 - 185                                 |
| 5   | 4 - 120                                 |
| 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 24, 27, 30, 37 | 1,5 2,5                                 |

# **Application/Limitation**

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

## **Type Approval documentation**

Data sheet: TEOF P18 RU 0,6/1kV - RU Mud 0,6/1kV rev. 00 dated 05/114. Test reports.

### **Tests carried out**

|                | Release | General description  | Limitation  |
|----------------|---------|--|---|
| DNVGL-CP-0399  | 2016-03 | Class Programme Electric cables  |   |
| IEC 60092-350  | 2014-08 | General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications   |   |
| IEC 60092-360  | 2014-04 | Electrical installations in ships - Part 360:<br>Insulating and sheathing materials for<br>shipboard and offshore units, power,<br>control, instrumentation and<br>telecommunication cables. |   |
| IEC 60092-353  | 2016-09 | Electrical installations in ships - Part 353:<br>Power cables for rated voltages 1 kV and 3<br>kV  |   |
| IEC 60332-1-2  | 2006-07 | Tests on eletric cables under fire conditions. Test for vertical flame propagation for a single insulated wire or cable.   |   |
| IEC 60332-3-22 | 2018-07 | Tests on electric cables under fire conditions - Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables - Category A  | Charred portion of sample does not exceed 2,5m above bottom edge of burner. |
| IEC 60754-1    | 2011-11 | Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content   | Low Halogen:<br><0,5% Halogen   |

Form code: TA 251 Revision: 2016-12 www.dnvgl.com Page 2 of 3

Job Id: **262.1-015325-7** Certificate No: **TAE00002ZB** 

|               | Release | General description                         | Limitation                    |
|---------------|---------|---|-------------------------------|
| IEC 60754-2   | 2011-11 | Test on gases evolved during combustion     | Halogen free:                 |
|               |         | of materials from cables - Part 2:          | pH > 4,3                      |
|               |         | Determination of acidity (by pH             | Conductivity <                |
|               |         | measurement) and conductivity               | 10μS/mm                       |
| IEC 61034-1/2 | 2013-07 | Measurement of smoke density of cables      | Low smoke                     |
|               | 2013-09 | burning under defined conditions –          | Light                         |
|               |         | Test apparatus, procedure and               | transmittance <u>&gt;</u> 60% |
|               |         | requirements                                |                               |
| NEK 606 Ed. 4 | 2009-05 | Cables for offshore installations. Halogen- |                               |
|               |         | free and/or mud resistant. Technical        |                               |
|               |         | specification.                              |                               |

# **Marking of product**

PRYSMIAN SAP - TEOF or EXZHELLENT 606 - P18 RU or RU MUD - size - 0,6/1 kV - IEC 60332-3-22 - Lot No

### **Periodical assessment**

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine tests (RT) and selected type tests (ref. to applicable class programs) checked (if not available these tests shall be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

**END OF CERTIFICATE** 

Form code: TA 251 Revision: 2016-12 www.dnvgl.com Page 3 of 3